

**Official Publication No. 8501**

Procurement Division  
330 2<sup>nd</sup> Ave South, Room 552  
Minneapolis, MN 55401

AN AFFIRMATIVE ACTION EMPLOYER

January 12, 2018

Buyer Information:  
Traci Reimringer, (612) 673-2176  
[Traci.Reimringer@minneapolismn.gov](mailto:Traci.Reimringer@minneapolismn.gov)

---

**ADDENDUM NO. 4**  
**“Bids for MCC Expansion Restroom Remodel Project”**

**Questions & Answers**

- 1) Who is responsible for supplying the Hand Dryers? **That is a General Contractor decision.**
- 2) Toilet Roll Holders: Per Georgia Pacific: The specified Georgia Pacific models are supplied free of charge to the facility owner that has a signed paper agreement with Georgia Pacific and cannot be purchased by a contractor. Please confirm these will be available through MCC. **Owner provided, GC to install.**
- 3) Regarding the Hadrian Standard Series per Addendum 03, are we to supply the full height brackets and the "no-sight line" door hardware system with the Standard system? **Yes, and doors and panels shall be 12" off of the floor.**
- 4) In the smaller restrooms they do not specified base? I tried to see if there is a matching cove for the CTW-3 wall tile and there is not. I know when I walked the MCC there was tile base in the smaller restroom (Single), which tile should I use for these restrooms? **There is not a coordinating base for CTW3. But, since all floor to wall transitions utilize a schulter strip cove per detail 9/A12.000, a coved tile base is not required.**

**Receipt of this addendum should be acknowledged on your bid form.**

Please consider any changes and/or corrections as part of the original bid specifications and submit your bid accordingly.

**Bids opened 10:00 AM, Local Time, January 17<sup>th</sup>, 2018**

Finance and Property Services – Procurement Division  
City of Minneapolis